

# Vanleer Water System Water Quality Report 2020

## Is my drinking water safe?

Yes, our water meets all of EPA's health standards. We have conducted numerous tests for over 80 contaminants that may be in drinking water. As you'll see in the chart on the back, we only detected six of these contaminants. We found all of these contaminants at safe levels.

## What is the source of my water?

Part of your water, which is ground water under the influence of surface water, comes from the Columbia Caverns Spring. Part of your water, which is surface water, comes from Yellow Creek. Our goal is to protect our water from contaminants and we are working with the State to determine the vulnerability of our water source to *potential* contamination. The Tennessee Department of Environment and Conservation (TDEC) has prepared a Source Water Assessment Program (SWAP) Report for the untreated water sources serving this water system. The SWAP Report assesses the susceptibility of untreated water sources to *potential* contamination. To ensure safe drinking water, all public water systems treat and routinely test their water. Water sources have been rated as reasonably susceptible, moderately susceptible or slightly susceptible based on geologic factors and human activities in the vicinity of the water source. The Vanleer Water System sources rated as reasonably susceptible to potential contamination.

An explanation of Tennessee's Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed online at <https://www.tn.gov/environment/program-areas/wr-water-resources/water-quality/source-water-assessment.html> or you may contact the Water System to obtain copies of specific assessments.

A wellhead protection plan is available for your review by contacting Gary Trotter at the Vanleer Water System between 7:00 A.M. to 3:00 P.M. weekdays.

## Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Este informe contiene información muy importante. Tradúscalo o hable con alguien que lo entienda bien.

For more information about your drinking water, please call Gary Trotter at 615-763-2823.

## How can I get involved?

Our Water Board meets on the fourth Monday of each month at 7:00 pm at the Town Hall, which is located at 4714 Hwy 49 West. Please feel free to participate in these meetings.

## Is our water system meeting other rules that govern our operations?

The State and EPA require us to test and report on our water on a regular basis to ensure its safety. We have met all of these requirements. Results of unregulated contaminant analysis are available upon request. We want you to know that we pay attention to all the rules.

## Other Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and the Tennessee Department of Environment and Conservation prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. Vanleer Water System's water treatment processes are designed to reduce any such substances to levels well below any health concern. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

## Do I Need To Take Special Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have under-gone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about not only their drinking water, but food preparation, personal hygiene, and precautions in handling infants and pets from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

## Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Vanleer Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

## Water System Security

Following the events of September 2001, we realize that our customers are concerned about the security of their drinking water. We urge the public to report any suspicious activities at any utility facilities, including treatment plants, pumping stations, tanks, fire hydrants, etc. to 615-763-2823

## Pharmaceuticals In Drinking Water

Flushing unused or expired medicines can be harmful to your drinking water. Learn more about disposing of unused medicines at <http://tdeconline.tn.gov/rxtakeback/>.

# Water Quality Data

## What does this chart mean?

- **MCLG** - Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL** - Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.
- **MRDL**: Maximum Residual Disinfectant Level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.
- **MRDLG**: Maximum residual disinfectant level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **AL** - Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **Below Detection Level (BDL)** - laboratory analysis indicates that the contaminant is not present at a level that can be detected.
- **Non-Detects (ND)** - laboratory analysis indicates that the contaminant is not present.
- **Parts per million (ppm) or Milligrams per liter (mg/l)** – explained as a relation to time and money as one part per million corresponds to one minute in two years or a single penny in \$10,000.
- **Parts per billion (ppb) or Micrograms per liter** - explained as a relation to time and money as one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- **Nephelometric Turbidity Unit (NTU)** - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- **RTCR** – Revised Total Coliform Rule. This rule went into effect on April 1, 2016 and replaces the MCL for total coliform with a Treatment Technique Trigger for a system assessment.
- **TT** - Treatment Technique, or a required process intended to reduce the level of a contaminant in drinking water.

Contaminant	Violation Yes/No	Level Found	Range of Detections	Date of Sample	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (RTCR)	No	0		2020		0	TT Trigger	Naturally present in the environment
Turbidity <sup>1</sup>	No	0.1		2020	NTU	n/a	TT	Soil runoff
Copper <sup>2</sup>	No	90 <sup>th</sup> % = 0.1279		2020	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead <sup>2</sup>	No	90 <sup>th</sup> % = ND		2020	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sulfate	No	8.68	7.9-8.68	2020	ppm	N/A	N/A	
Sodium	No	4.67	4.56-4.67	2020	ppm	N/A	N/A	Erosion of natural deposits; used in water treatment
TTHM [Total trihalomethanes]	No	10.81	Nd-28.5	2020	ppb	n/a	80	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	No	14.21	ND-44.4	2020	ppb	N/A	60	By-product of drinking water disinfection.
Total Organic Carbon <sup>3</sup>	No	See footnote 3		2020	ppm	TT	TT	Naturally present in the environment.
Chlorine	No	AVG 1.78	1.7-2.2	2020	ppm	MRDLG 4	MRDL 4	Water additive used to control microbes.

<sup>1</sup>100% of our samples were below the turbidity limit.

<sup>2</sup>During the most recent round of Lead and Copper testing, 0 out of 20 households sampled contained concentrations exceeding the action level.

<sup>3</sup>We have met all treatment technique requirements for Total Organic Carbon removal.



## You may choose to use the option of electronic delivery of your CCR.

If you publish your Consumer Confidence Report on a website, you should take the following steps:

1. Post the complete Consumer Confidence Report on a publicly available site on the internet.
2. Post a notice on your water bills or in a direct mailing. The following is a minimal statement that we've had approved by TDEC. You can add more if you wish.

**Our Annual Water Quality Report containing important information about the source and quality of your drinking water can now be viewed online at [vcenterwaterworks.com](http://vcenterwaterworks.com). For a paper copy of the report call [615-763-9823](tel:615-763-9823).**

*This notice must be printed on all water bills mailed for three consecutive months. The first printing must be delivered to customers in the month of June or earlier.*

3. The Uniform Resource Locator (URL) printed on the water bill or notification **must take customers directly to the CCR** on a publicly available site on the internet where it can be viewed. Customers cannot be required to follow links to view the CCR.
4. You should make "good faith" efforts to insure that persons who do not receive a water bill are aware of your CCR. These may include:
  - Post copies of the report in local libraries and other public buildings where it can be viewed by the public.
  - Provide copies of the CCR to places with multiple residents such as apartments, nursing homes, etc.
  - Make copies available at your office.
5. **You must keep a list of all customers requesting hard copies of CCRs and the date the CCR was mailed and/or delivered to the customer.** If you are aware of a customer's inability to receive a CCR by the electronic delivery method used, you must provide the CCR to the customer by an alternative method.
6. Send the completed certification form along with a paper copy of the CCR and a copy of the water bill with notice or mailed notice to the Division of Water Resources in Nashville. You may also wish to provide copies to your local Division of Water Resources field office. **The new address for Nashville Division of Water Resources is:**  
William R. Snodgrass TN Tower  
312 Rosa Parks Ave.  
11<sup>th</sup> Floor  
Nashville, TN 37243

You are also now allowed to email the CCR as a pdf attachment to:

[DWRWater.Compliance@tn.gov](mailto:DWRWater.Compliance@tn.gov)

The subject line should be: (Your Utility Name) 2020 CCR, (P.W.S.I.D.)

If you have any questions, you can contact the TAUD office at 615-896-9022 or call the following TAUD employees on their cellular phones:

- Greg Baker 731-225-5240
- Johnny Walker 731-261-5826
- Adam Hale 423-418-2283
- Tony Wyatt 731-415-9101

**Remember, the report must be made available to customers before July 01, 2021.**

**TAUD's staff will make every effort to assist you in completing an accurate CCR based on the information provided. However, it is the operator who is responsible for its content. You should always review all information and calculations before publishing your report.**